

- 4. BEAMS MUST BE LOCATED UNDER THE FULL LENGTH OF THE PAN SECTION.
- 5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY
- PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.

10.THE CENTER BEAM SHOULD HAVE A MINIMUM WIDTH OF 12" [305mm] 11. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN

STEEL BEAMS AND THE UNIT.

[METRIC] [mm]