UNIT	UNIT COOLING TOWER	
MODEL #	AT 112-3O18	SCALE NTS

EVAPCO, INC. Evapco



DWG. # REV. T3121836-DRD-ST DATE 7/14/2025 SERIAL #

NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT **DRAWING**
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]


FACE C


ACCESS DOOR

FACE B PLAN VIEW

FACE D

FACE A





DRAWN BY: KDS NO. OF SHIPPING SECTIONS **SHIPPING OPERATING** HEAVIEST SECTION 11920 lbs+ [5410] kg+ 21190 lbs+ [9615] kg+ 8020 lbs+ [3640] kg+ WEIGHT WEIGHT WEIGHT