| ATWD 10-0L24   | SCALE NTS              | FVAP(()   |   |                |                 |
|--|------------------------|---|---|----------------|-----------------|
| NOTES  | IVIS                   | LVAI CO,  | INC. evapeo   | SERIAL #       | DATE 8/27/2025  |
| NOTES:  1. (M)- FAN MOTOR LOCATION  2. HEAVIEST SECTION IS UPPER SECTION  3. MPT DENOTES MALE PIPE THREAD  FPT DENOTES FEMALE PIPE THREAD  BFW DENOTES BEVELED FOR WELDIG  GVD DENOTES GROOVED  FLG DENOTES FLANGE  PE DENOTES PLAIN END  4. +UNIT WEIGHT DOES NOT INCLUDE  ACCESSORIES (SEE ACCESSORY DR.  5. MAKE-UP WATER PRESSURE  20 psi MIN [137 kPa], 50 psi MAX [344 kl.  6. *-APPROXIMATE DIMENSIONS DO NOTE FOR PRE-FABRICATION OF CONNECT PIPING  7. 3/4" [19mm] DIA. MOUNTING HOLES. RECOMMENDED STEEL SUPPORT DR.  8. DIMENSIONS LISTED AS FOLLOWS:  ENGLISH FT-IN  METRIC [mm] | AWINGS) Pa] T USE TING | PLAN V  | ACE B  IEW  FACE  | ACCESS DOOR  F | ACE D           |
| 3'-3 1/4" *<br>[ 997]  |                        | 9'-8 5/8" [ 2964]  15'-10 7/8" [ 4848]  * 6'-2 1/4" [ 1884] | 1'-3 1/4" (4) 1/2" [15] FPT VENT  11'-11 3/4" [ 3651]  1'-5" [ 432] |                | 1'-5"<br>[ 432] |