
ATWB 12-7M14-Z

UNIT

TITLE

STEEL SUPPORT CONFIGURATION



DWG. #

SCALE

SLAW1214-DD

DRAWN BY

5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.