UNIT ATWB 7-6J36
TITLE STEEL SUPPORT CONFIGURATION

EVAPCO, INC. Evapea

DWG. # SLAWC0736-DA


SCALE N.T.S. DRAWN BY TAM

36'-2 1/2"
[11036]

[11036]

[11036]

[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[12]



TYPICAL END VIEW

PLAN VIEW

NOTES:

- BEAMS SHOULD BE SIZED IN ACCORDANCE WITH ACCEPTED STRUCTURAL PRACTICES.
 MAXIMUM DEFLECTION OF BEAM UNDER UNIT TO BE 1/360 OF UNIT LENGTH NOT TO EXCEED 1/2" [13mm].
- DEFLECTION MAY BE CALCULATED BY USING 55% OF THE OPERATING WEIGHT AS A UNIFORM LOAD ON EACH BEAM. SEE CERTIFIED PRINT FOR OPERATING WEIGHT.
- 3. SUPPORT BEAMS AND ANCHOR HARDWARE ARE TO BE FURNISHED BY OTHERS. ANCHOR HARDWARE TO BE ASTM A325 5/8" [16mm] BOLT OR EQUIVALENT.
- 4. BEAMS MUST BE LOCATED UNDER THE FULL LENGTH OF THE PAN SECTION.
- SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.

- 6. THE FACTORY RECOMMENDED STEEL SUPPORT CONFIGURATION IS SHOWN. CONSULT THE FACTORY FOR ALTERNATE SUPPORT CONFIGURATIONS.
- 7. UNIT SHOULD BE POSITIONED ON STEEL SUCH THAT THE ANCHORING HARDWARE FULLY PENETRATES THE BEAM'S FLANGE AND CLEARS THE BEAM'S WEB.
- 8. FOR ALL MULTIPLE CELL UNITS, OPERATING WEIGHT OF EACH CELL IS FOUND BY DIVIDING TOTAL OPERATING WEIGHT BY THE NUMBER OF CELLS.
- 9. WHEN VIBRATION ISOLATION IS REQUIRED, THE VIBRATION ISOLATORS (BY OTHERS)
 MUST BE LOCATED UNDER THE SUPPORTING STEEL BEAMS AND NOT BETWEEN THE SUPPORTING
 STEEL BEAMS AND THE UNIT.
- 10. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]