UNIT COOLING TOWER	EVAPCO, INC. EVGPCO SERIAL # TV05061P-DRE-ST	REV.
MODEL # LPT-526 SCALE NTS	EVAPCO, INC. SERIAL #	DATE 9/4/2025
NOTES: 1. (M) FAN MOTOR LOCATION 2. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 3. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 4. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING 5. MAKE-UP WATER PRESSURE-20 psi MIN, 50 psi MAX 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] MM	FACE B PLAN VIEW	FACE D
	FACE A	
2'-6 3/8" [772] 4" [100] MPT INLET 3'-1/4" [919] 4 3/4" - 4" [100] MPT OUTLET (*)	6'-1 7/8" [1805] 6'-1 7/8" [1876] 6'-10 5/8" ACCESS DOOR 3" [75] MPT OVERFLOW 2" [50] MPT DRAIN 1 3/8" [1805] 1 3/8" [1805] 2 2/1/4" [1805]	6'-7 3/4" [2026]

12'-2 7/8" . [3731]

FACE A

5'-3/4" [1544]

FACE B