| COOLING TOWER | | | | NDCO T | NC ev | apco | wg. # AX122217-DRA | AX122217-DRA-ST REV. | |
|--|---|--|----------------------------|---------------------|----------------------------|---------------------------------------|---|---|--|
| MODEL # | AXS 12-19l22 | SCALE | T EVA | APCO, I | NC. | S | ERIAL # | DATE 9/5/2025 | |
| 2. HEAVIEST 3. MPT DENC FPT DENC BFW DENC GVD DENC 4. +UNIT WE ACCESSO 5. MAKE-UP' 20 psi MIN 6. 3/4" DIA. M RECOMME | IOTOR LOCATION SECTION IS UPPER SECTOTES MALE PIPE THREAD TES FEMALE PIPE THREAD OTES BEVELED FOR WEL OTES GROOVED GHT DOES NOT INCLUDE RIES (SEE ACCESSORY D WATER PRESSURE [137 kPa], 50 psi MAX [344 OUNTING HOLES. REFER ENDED STEEL SUPPORT INS LISTED AS FOLLOWS: | AD DING E DRAWINGS) kPa] TO DRAWING. | | FACE B PLAN VIEW | 5'-11" 1804] | FACE C ACCESS DOOR | | FACE D (2) 8" [200] ASME 150 FLG PATTERN INLET | |
| | | | 7" [178] | | | FACE A | | | |
| | | | 9'-4 3/8" [2855] | ļπ | | | · · · · · · · · · · · · · · · · · · · | — 4" [100] FPT OVERFLOW | |
| | | | 9'-11 5/8" | <u>•</u> | <u> </u> | ACCESS DOOR | | 3" [80] MPT MAKE-UP 4" [100] FPT DRAIN | |
| | ļ <u>.</u> (| 11'-10" 3607] <u>FACE</u> | 3/8" [10] | 3 7/8" | | [300] BFW/GVD OUTLET 22'-9" [6934] | 9'-3" [2819] 10'-1" [3073] 11'-4 1/2" [3467] | | |
| SHIPPING WEIGHT | 16410 lbs+ [7445] l | kg+ | OPERATING WEIGHT 37350 lbs | s+ [16945] kg+ | HEAVIEST SECTION WEIGHT | 9220 lbs+ [4185] kg+ | NO. OF SHIPPING SECTIONS | 2 DRAWN BY: JLM | |