UNIT	COOLING TOWER	FVAPCO INC evapco DWG. # AX142420-DRA-ST REV.
MODEL #	S 14-22M24	EVAPCO, INC. evapco SERIAL # DATE 5/19/2024
2. HEAVIEST S 3. MPT DENOTE FPT DENOTE BFW DENOTE GVD DENOTE 4. +UNIT WEIG ACCESSORI 5. MAKE-UP W 20 psi MIN [1: 6. 3/4" DIA. MO RECOMMEN	TOR LOCATION ECTION IS UPPER SECTION ES MALE PIPE THREAD ES FEMALE PIPE THREAD ES BEVELED FOR WELDING ES GROOVED HT DOES NOT INCLUDE ES (SEE ACCESSORY DRAWINGS) ATER PRESSURE 37 kPa], 50 psi MAX [344 kPa] UNTING HOLES. REFER TO DED STEEL SUPPORT DRAWING. S LISTED AS FOLLOWS: ENGLISH [METRIC]	
	13'-11 1/4" ————————————————————————————————————	11'-4 1/4" [3462] 11'-2 5/8" [3418] - 3/8" - (10) FPT OVERLOW 37/8" ACCESS DOOR 4" [100] FPT OVERLOW 37 [80] MPT MAKE-UP 4" [100] FPT OVERLOW 37/8" 14" [350] BFW/GVD OUTLET 11'-11' [3378] [13-4 1/2" [3772]
SHIPPING WEIGHT	22630 lbs+ [10265] kg+	OPERATING WEIGHT 49280 lbs+ [22355] kg+ HEAVIEST SECTION 12880 lbs+ [5845] kg+ NO. OF SHIPPING SECTIONS 2 DRAWN BY: SLR