UNIT ESW4 9-44J9-LP
TITLE STEEL SUPPORT CONFIGURATION

EVAPCO, INC. Evapeo

DWG. # SLWX40909-DA

SCALE N.T.S. DRAWN BY TAM

8'-11 1/2"
[2730]

8'-11 1/2"
[203]
[203]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]
[127]

TYPICAL END VIEW

UNIT

NOTES:

13/16" [21]

 BEAMS SHOULD BE SIZED IN ACCORDANCE WITH ACCEPTED STRUCTURAL PRACTICES.
 MAXIMUM DEFLECTION OF BEAM UNDER UNIT TO BE 1/360 OF UNIT LENGTH NOT TO
 EXCEED 1/2" [13mm].

PLAN VIEW

- 2. DEFLECTION MAY BE CALCULATED BY USING 55% OF THE OPERATING WEIGHT AS A UNIFORM LOAD ON EACH BEAM. SEE CERTIFIED PRINT FOR OPERATING WEIGHT.
- 3. SUPPORT BEAMS AND ANCHOR HARDWARE ARE TO BE FURNISHED BY OTHERS. ANCHOR HARDWARE TO BE ASTM A325 5/8" [16mm] BOLT OR EQUIVALENT.
- 4. BEAMS MUST BE LOCATED UNDER THE FULL LENGTH OF THE PAN SECTION.
- 5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.

- 6. THE FACTORY RECOMMENDED STEEL SUPPORT CONFIGURATION IS SHOWN. CONSULT THE FACTORY FOR ALTERNATE SUPPORT CONFIGURATIONS.
- 7. UNIT SHOULD BE POSITIONED ON STEEL SUCH THAT THE ANCHORING HARDWARE FULLY PENETRATES THE BEAM'S FLANGE AND CLEARS THE BEAM'S WEB.
- 8. WHEN VIBRATION ISOLATION IS REQUIRED, THE VIBRATION ISOLATORS (BY OTHERS) MUST BE LOCATED UNDER THE SUPPORTING BEAMS AND NOT BETWEEN THE SUPPORTING STEEL BEAMS AND THE UNIT.
- 9. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]

MOUNTING HOLE