
UNIT	COOLING TOWER		
MODEL #	AT 29-3J21	SCALE NTS	

EVAPCO, INC. Evapeo

DWG. #	T3092136-DRE-ST	REV
SERIAL #		DATE 8/28/2025


NOTES:


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED**
- FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE
- 20 psi MIN [137 kPa], 50 psi MAX [344 kPa] 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMENDED STEEL SUPPORT DRAWING.
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]



FACE D

FACE A





DRAWN BY: JLG SHIPPING NO. OF SHIPPING SECTIONS OPERATING HEAVIEST SECTION 10210 lbs+ [4635] kg+ 17150 lbs+ [7780] kg+ 7020 lbs+ [3185] kg+ WEIGHT WEIGHT WEIGHT