UNIT COOLING TOWER				DWG. # T32M1824-DRE-ST	
MODEL #	NTS EVAP	CO, INC.	evapco	SERIAL #	DATE 7/19/2025
NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS UPPER SECTION 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWING 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa] 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER RECOMENDED STEEL SUPPORT DRAWING 7. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]	R ТО	FACE B PLAN VIEW	(M) AC	FACE C CCESS DOOR ACCESS DOOR ACCESS DOOR	FACE D
				FACE A	
1'-9 3/8" [543]	1'-7/8" [327]	8'-3 1/2" [2527] 2" 1'-11 1/8"	[50] MPT — MAKE-UP — 3" [80] FPT OVERFLOW — 6	8" [200] W/GVD ET	

FACE A

- 7'-10" [2388] -**FACE B**