EVAPCO, INC. UNIT MODEL # DATE SERIAL # **CLOSED CIRCUIT CLOOLER** NTS WZ12124808-MRA-RS ATC-XE1032E 6/30/2025 NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS LOWER SECTION **BOTTOM OUTLET** 3. MPT DENOTES MALE PIPE THREAD 1826 (M) FPT DENOTES FEMALE PIPE THREAD 613 BFW DENOTES BEVELED FOR WELDING 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 5. 19mm DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT 3607 6. THE SPRAY PUMP SHOULD BE SIZED FOR 65 L/S AND 31 kPa AT THE INLET CONNECTION FACE 2 7. * - APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF CONNECTING **PLAN VIEW** PIPING 3651 FACE 1 - 178 105 **ACCESS** DOOR – 1803 – 3150 200 FLG. INLET 5398 (2) 100 BFW (2) 15 FPT **FLUID OUT VENT** 3741 2248 (2) 100 BFW 1219 686 FLUID IN 581 - 1194 3651 3607 FACE 1 FACE 2 NO. OF SHIPPING SECTIONS SHIPPING OPERATING HEAVIEST SECTION 7790 kq 9640 kg 4930 2 WEIGHT WEIGHT WEIGHT