EVAPCO, INC. UNIT MODEL # DWG. # DATE SERIAL # **CLOSED CIRCUIT COOLER** NTS W2090808-ERC-RS 6/19/2025 eco-ATC-1106A NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS UPPER SECTION **BOTTOM OUTLET** (M) 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD 18 1/8 BFW DENOTES BEVELED FOR WELDING 50 3/4 4. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 5. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT 7'-5 7/8" 6. THE SPRAY PUMP SHOULD BE SIZED FOR 340 GPM AND 2.5 PSIG AT THE INLET CONNECTION 7. *- APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF CONNECTING FACE 2 **PIPING** 8'-5 1/2" FACE 1 **PLAN VIEW** 21 3/8 + ACCESS DOOR - 22 5/8 1 3/8 85 7/8 11 1/8 4 FPT Ó-**INLET** (2)1/2 FPT VENT (2) 4 BFW FLUID IN 11'-2" 27 (2) 4 BFW **FLUID OUT** 0-5 1/8 48 1/8 7'-5 7/8" 8'-5 1/2" FACE 2 FACE 1 NO. OF SHIPPING SECTIONS SHIPPING OPERATING HEAVIEST SECTION lbs.+ 8320 10990 7020 lbs. 2 lbs. WEIGHT WEIGHT WEIGHT