			Taura #	I
UNIT COOLING TOWER MODEL # AT 17-3J12 SCALE NTS EVAPCO, INC. EVAPCO* SERIAL # CT4C071236-DRA-ST SERIAL #			REV.	
MODEL # AT 17-3J12 SCALE NT:	EVAPCO, I	IVC.	SERIAL #	DATE 12/5/2025
NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS FAN/CASING SECTION 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS) 5. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm] 7. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]	1¹-2" [356]	FACE B PLAN VIEW	FACE C ACCESS DOOR FACE A	FACE D
8" [200] BFW/GVD INLET 3" [80] MPT OVERFLOW 8" [200] BFW/GVD OUTLET	2" [50] MPT 8'-7 3/8" [2624] 3" [80] MPT DRAIN 4 1/4" [107] 1'-111 1/8" [587] 5 1/4" [132] 7 1/2" [378] 1'-9 1/4" [190] 3 5/8" [91] E B	2'-11 3/8" [899] 12'-8 3/8" [1654] [51] 4'-3 7/8" [1318] 1 3/8" [35]	11'-111 3/4" FACE A	
SHIPPING 5160 lbs+ [2345] kg+	OPERATING 8520 lbs+ [3865] kg+	HEAVIEST SECTION 3510 lbs+ [1595] kg+	NO. OF SHIPPING SECTIONS 2	DRAWN BY: MBG