UNIT	COOLING TOWER	
MODEL #	AT 312-2J42	SCALE NTS

EVAPCO, INC. Evapco

**FACE B** 

**PLAN VIEW** 

WEIGHT


DWG. # REV. T3124224-DRE-ST DATE 11/5/2025 SERIAL #

## NOTES:

WEIGHT


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]

## **FACE C**



**FACE D** 

## **FACE A**



WEIGHT