UNIT **COOLING TOWER** MODEL # SCALE NTS AT 14-2E4


EVAPCO, INC. Evapeo




DWG. # REV. T3040424-DRJ-ST DATE<sub>11/12/2025</sub> SERIAL #


- 1. (M)- FAN MOTOR LOCATION
- 2. HEAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMENDED STEEL SUPPORT DRAWING.
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]





**FACE A** 





DRAWN BY: KWC NO. OF SHIPPING SECTIONS **SHIPPING** OPERATING HEAVIEST SECTION 1080 lbs+ [490] kg+ 1710 lbs+ [780] kg+ 730 lbs+ [335] kg+ WEIGHT WEIGHT WEIGHT