UNIT	COOLING TOWER	
MODEL #	AT 312-2I42	SCALE NTS

EVAPCO, INC. Evapco

**FACE B** 

**PLAN VIEW** 

DWG. #	T3124224-DRE-ST	REV.
SERIAL #		DATE <sub>12/13/2025</sub>

## NOTES:

WEIGHT


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT

25560 lbs+ [11595] kg+

WEIGHT

7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]


## **FACE C**



FACE D

## **FACE A**

5360 lbs+ [2435] kg+



WEIGHT

47550 lbs+ [21570] kg+