UNIT	COOLING TOWER		
MODEL #	AT 312-2M60	SCALE NTS	

EVAPCO, INC. Evapeo

DWG. #	T3126024-DRD-ST	REV
SERIAL #		DATE 9/6/2025


NOTES:


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD
 FPT DENOTES FEMALE PIPE THREAD
 BFW DENOTES BEVELED FOR WELDING
 GVD DENOTES GROOVED
 FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES.

 REFER TO RECOMMENDED STEEL SUPPORT PLAN VIEW


 PLAN VIEW
- 7. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]

FACE B





FACE C



FACE D

FACE A

