
ATWB 3-4C3-Z

UNIT

TITLE

STEEL SUPPORT CONFIGURATION



EVAPCO, INC.

DWG. #

SCALE

N.T.S.

SLAW30303-DD

DRAWN BY

JLG

5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.