UNIT COOLING TOWER		EVAPCO, INC. Evapeo			DWG. # TV05063F-DRE-ST	REV.
MODEL # LPT-596	SCALE NTS	EVAPCO,	INC.		SERIAL #	DATE 9/6/2025
NOTES: 1. (M)- FAN MOTOR LOCATION 2. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 3. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWIN FOR ACCESSORIES) 4. 3/4" DIA. MOUNTING HOLES. REFER T RECOMMENDED STEEL SUPPORT DRAWING 5. MAKE-UP WATER PRESSURE-20 psi MIN 50 psi MAX 6. DIMENSIONS LISTED AS FOLLOWS ENGLISH FT-IN [METRIC] MM	NGS O	FA PLAN VI	ACE B	FACE		FACE D
				FACE	A	
2'-6 3/8 [772] 4'-10 3/8" [1484] 3'-1/4" [919] 4 3/4" - 4" OL 4 3/4" 5 1 [14	4" [100] MPT INLET TYP. [100] MPT TILET	7'-1 7/8" [2181] 8 3/4" [222] 1'-8 1/8" [511] 2 3/4" [70]	7'-10 5/8" [2403]	ACCESS — DOOR 3" [75] MPT — 2" [50] MPT — 1		6'-7 3/4" [2026]

FACE A

NO. OF SHIPPING SECTIONS

DRAWN BY: JLG

FACE B