COOLING TOWER			E\/A	DCO I		/apco	wg. # AX122217-DRA	AX122217-DRA-ST REV	
MODEL #	AXS 12-19Q22	SCALE	T EVA	PCO, I	NC.	SE	ERIAL #	DATE 12/8/2025	
2. HEAVIEST 3. MPT DENG FPT DENG BFW DEN GVD DENG 4. +UNIT WE ACCESSO 5. MAKE-UP 20 psi MIN 6. 3/4" DIA. N RECOMME	MOTOR LOCATION  SECTION IS UPPER SECTOTES MALE PIPE THREAD  DITES FEMALE PIPE THREAD  DITES BEVELED FOR WEL  DITES GROOVED  IGHT DOES NOT INCLUDE  RIES (SEE ACCESSORY DE  WATER PRESSURE  [137 kPa], 50 psi MAX [344  IOUNTING HOLES. REFER  ENDED STEEL SUPPORT INS LISTED AS FOLLOWS:	AD DING  E DRAWINGS)  kPa] R TO DRAWING.		FACE B PLAN VIEW	5'-11" 1804 ] 	FACE C ACCESS DOOR		FACE D  (2) 8" [200] ASME 150 FLG PATTERN INLET	
			7" [ 178 ] _			FACE A			
			9'-4 3/8"			(÷	) )	— 4" [100] FPT OVERFLOW	
			9'-11 5/8"	<u>↓</u>	<b>1</b>	ACCESS DOOR		3" [80] MPT MAKE-UP 4" [100] FPT DRAIN	
	ļ <u>-</u> [	11'-10" 3607 ] <b>FACE</b>	3/8" [ 10 ]	3 7/8"		[300] BFW/GVD OUTLET  22'-9" [6934]	9'-3" [ 2819 ] 10'-1" [ 3073 ] — 11'-4 1/2" [ 3467 ]		
SHIPPING WEIGHT	17290 lbs+ [7845]	kg+	OPERATING WEIGHT 38230 lbs	+ [17345] kg+	HEAVIEST SECTION WEIGHT	10110 lbs+ [4590] kg+	NO. OF SHIPPING SECTIONS	2 DRAWN BY: JLM	