
eco-ATC-644A

UNIT

STEEL SUPPORT CONFIGURATION



DWG. #

SLAW1214-DD

5. SUPPORTING BEAM SURFACE MUST BE LEVEL, DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.