CONFIDENTIAL

This document is the property of Evapco, Inc. It should not be copied or disclosed without prior written authorization.

PROJECT

EVAPCO, INC.



N.T.S. CUSTOMER EJETME1-1146B0050F3KA EJETME1-SE-16 7/14/2025 NOTES: 1) * = HANGER HOLE LOCATION. 2) RIGHT HAND MODEL SHOWN. 3) HANGER HOLES ARE FOR 3/4 INCH THREADED ROD. 4) WATER DEFROST ADDS 1 3/4" INCHES TO HEIGHT OF STANDARD UNIT AND CHANGES DRAIN SIZE. 5) ALL DIMENSIONS ARE FOR REFERENCE AND SHOULD NOT BE USED FOR PREFABRICATION OF PIPING OR SUPPORTS. 6) **= HEIGHT OF SUCTION HEADER AND INSTALLED THERMOWELL FITTING ABOVE CABINET. CUSTOMER IS RESPONSIBLE TO ACCOUNT FOR ADDITIONAL HEIGHT NECESSARY FOR RTD AND ACCESS. - 46 3/8 — * 41 3/8 ---67 1/4 **→** 19 1/4 ** 6 1/8 48 1/4 56 5/8 FLOW

