UNIT COOLING TOWER			DCO T	NC eve	apco	DWG. # T4285260-DRA-ST	REV.
10DEL # AT 428-5M52	SCALE NTS	T EVA	APCO, I	NC.		SERIAL #	DATE 9/10/2025
NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS UPPER SECTION 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES PLAIN END 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS) 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 KPa], 50 psi MAX [344 KPa] 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING 7. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm] 8. PAN FLUME BOX EQUALIZERS SUPPLIED BY EVAPCO. PAN EQUALIZER PIPING IS SUPPLIED BY OTHERS. 9. PAN EQUALIZER NIPPLE IS 11'-10 3/8" [3616] OFF EACH STEP SIDE.			FACE B PLAN VIEW		(8) ACCESS DOOR		FACE D
		_ 1'-3 1/4" _ [387]	7" [178]		FACE F	<u>.</u>	
(4) 14" [350] BFW/GVD INLET		6'-11 5/8" [2124] 22'-3 1/ [6794	12'-1/4" [3664] [51]	00	60	00 00	2" [51]
		16'-3 3/4" [4972]	10'-3 1/4"				,
(4) 14" [350] ————————————————————————————————————	11'-6" [3505] 13'-1 1/4" [3994] 13'-5 1/2" [4102] 13'-6 1/2" [4128]	2'-2" [660] 1'-5 3/8" [441] 9" [229]			9 1/8" [232] 1 3/8" [35]	(4) 12" [300] BFW/GVD EQUALIZER (SEE NOTE #9) 3'-7" [1092]	
5 1/8"	13'-11 1/4"	4" [102]		1 7045			
28'-3 5/8" [8626] FACE B		1 1/2"					
SHIPPING 98600 lbs+ [44725] kg+		OPERATING 165160 WEIGHT) lbs+ [74920] kg+	HEAVIEST SECTION WEIGHT	17820 lbs+ [8085] kg+	NO. OF SHIPPING SECTIONS 8	DRAWN BY: MER