COOLING TOWER				® DWG. #	T3122C36-DRD-ST	REV
DEL # AT 212-3L36	SCALE NTS	EVAPCO, INC.		SERIAL #	SERIAL #	
NOTES: 1. (M)- FAN MOTOR LOCATIO 2. HEAVIEST SECTION IS UP 3. MPT DENOTES MALE PIPE FPT DENOTES FEMALE PIPE FPT DENOTES BEVELED GVD DENOTES GROOVED FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT ACCESSORIES (SEE ACCE 5. MAKE-UP WATER PRESSL 20 psi MIN [137 kPa], 50 psi 6. 3/4" [19MM] DIA. MOUNTIN REFER TO RECOMMENDE DRAWING 7. DIMENSIONS LISTED AS F ENGLISH FT-IN [METRIC] [mm]	PPER SECTION E THREAD IPE THREAD FOR WELDING) T INCLUDE ESSORY DRAWINGS) JRE i MAX [344 kPa] IG HOLES. ED STEEL SUPPORT	FACE B PLAN VIEW				FACE D
[]			<u>F</u>	ACE A		
	7" [178]	1'-3 1/4" [387]				
	[2"	 ₹ [-
	9'-4"		9'-0" (M) (M)		<u></u>	
	16'-6 1/ 16'-5 1/	4"			(2) 10" [250] BFW/GVD INLET	
	7'-2 1/4" [2191]	11'-1" [3378]			Q	
		2'-1 1/4"	9'-0" [2743]	(2) 3" [80] FPT OVERFLOW (2) 3" [80] FPT DAIN (2) 2" [50] MPT MAKE-UP	(2) 10" [250] BFW/GVD OUTLET	
111 101	2/01	3 5/8" _ [92]	18'-0" [5486]	MAKE-UP 2 1/2" [64]		

36'-2 1/2" [11036]

FACE A

11'-10" [3607]

FACE B