UNIT	COOLING TOWER	
MODEL #	AT 112-4J18	SCALE NTS

EVAPCO, INC. Evapeo



WG. #	T3121848-DRD-ST	REV
ERIAL #		DATE 8/15/2025

NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]

FACE C


ACCESS DOOR


FACE B PLAN VIEW

FACE D

DRAWN BY: KDS

FACE A





SHIPPING NO. OF SHIPPING SECTIONS OPERATING HEAVIEST SECTION 12120 lbs+ [5500] kg+ 21390 lbs+ [9705] kg+ 8220 lbs+ [3730] kg+ WEIGHT WEIGHT WEIGHT