
eco-LRWB 5-4I6-Z

UNIT

TITLE

STEEL SUPPORT CONFIGURATION



- 4. BEAMS MUST BE LOCATED UNDER THE FULL LENGTH OF THE PAN SECTION.
- 5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.

8. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]

DWG. #

SCALE

N.T.S.

SLAL30506-DC

DRAWN BY