
eco-LRWB 5-3J9-Z

UNIT

STEEL SUPPORT CONFIGURATION



DWG. #

SLAL30509-DC

5. SUPPORTING BEAM SURFACE MUST BE LEVEL. DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM.