
eco-LRWB 5-4J12-Z

UNIT

TITLE

STEEL SUPPORT CONFIGURATION



5. SUPPORTING BEAM SURFACE MUST BE LEVEL, DO NOT LEVEL THE UNIT BY PLACING SHIMS BETWEEN THE UNIT MOUNTING FLANGE AND THE SUPPORTING BEAM. [METRIC] [mm]

DWG. #

SCALE

SLAL30512-DC

DRAWN BY