UNIT COOLING TOWER	DWG. # TV05063F-DRE-ST	REV.
MODEL # LPT-536 SCALE NTS	EVAPCO, INC. EVAPCO SERIAL #	DATE 12/4/2025
NOTES: 1. (M) FAN MOTOR LOCATION 2. MPT DENOTES MALE PIPE THREAD FPT DENOTES SEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 3. + UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE SEPARATE DRAWINGS FOR ACCESSORIES) 4. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING 5. MAKE-UP WATER PRESSURE-20 psi MIN, 50 psi MAX 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] MM	FACE B PLAN VIEW	FACE D
	FACE A	
2'-63/8" [772] 4'-10 3/8" [1484]	[76]	
3 1/4" TYP.	7'-1 7/8" [2403] ACCESS — DOOR 3" [75] MPT — ACCESS — ACCESS — ACCESS — DOOR	6'-7 3/4" [2026]
3'-1/4" [919] 4" [100] MPT OUTLET (*) 4 3/4" [121] 5 1/2" [140]	OVERFLOW 2" [50] MPT	

FACE A

FACE B