UNIT	COOLING TOWER	
MODEL #	AT 19-3I11	SCALE NTS

EVAPCO, INC. Evapco


DWG. # REV. T3091136-DRD-ST DATE 9/12/2025 SERIAL #

NOTES:

- 1. (M)- FAN MOTOR LOCATION
 2. HEAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMENDED STEEL SUPPORT DRAWING.
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]





FACE B PLAN VIEW



FACE D

FACE A





DRAWN BY: JLG NO. OF SHIPPING SECTIONS **SHIPPING** OPERATING HEAVIEST SECTION 5050 lbs+ [2295] kg+ 8350 lbs+ [3790] kg+ 3450 lbs+ [1565] kg+ WEIGHT WEIGHT WEIGHT