UNIT	COOLING TOWER		
MODEL #	AT 112-3M12	SCALE NTS	



WG. #	T3121236-DRD-ST	REV.
ERIAL #		DATE 8/14/2025

NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES.
 REFER TO RECOMMENDED STEEL SUPPORT DRAWING
- 7. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]


FACE C






FACE D

FACE A





NO. OF SHIPPING SECTIONS 2 DRAWN BY: KDS

OPERATING WEIGHT

14350 lbs+ [6510] kg+

HEAVIEST SECTION WEIGHT

5740 lbs+ [2605] kg+