UNIT	COOLING TOWER	
MODEL #	AT 112-3L18	SCALE NTS

EVAPCO, INC. Evapeo




WG. #	T3121836-DRD-ST	REV
ERIAL #		DATE 8/14/2025

## NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT **DRAWING**
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]


## **FACE C**






FACE D

**FACE A** 





DRAWN BY: KDS NO. OF SHIPPING SECTIONS **SHIPPING** OPERATING HEAVIEST SECTION 11490 lbs+ [5215] kg+ 20760 lbs+ [9420] kg+ 7590 lbs+ [3445] kg+ WEIGHT WEIGHT WEIGHT