UNIT COOLING TOWER	FV/ADCO T	NC EV	apco	DWG. #	CT4C071836-DRA-ST	REV.
MODEL # AT 17-3G18 SCALE NTS	EVAPCO, I	NC.		SERIAL #		DATE 7/20/2025
NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS FAN/CASING SECTION 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS) 5. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm] 7. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]		FACE B AN VIEW	ACCESS	FACE A	ACCES	FACE D
1'-9 3/8" [543] 8" [200] BFW/GVD INLET	11'-2" [356] 31 -4 3, [4083	2'-11 3/8" [899] 			(M)	
3" [80] MPT — OVERFLOW	2" [50] MPT 9'-3 3/4" [2837] MAKE-UP 9'-3 3/4" [2837]	5'-1/4" [1530] 1 3/8"	-			
8" [200] BFW/GVD OUTLET 3'-1 [95 7'-4" [2235] FACE B SHIPPING WEIGHT 7910 lbs+ [3590] kg+	1'-9 1/4"	HEAVIEST SECTION WEIGHT	5280 lbs+ [2395] kg+	[5486] FACE A	PPING SECTIONS 2	DRAWN BY: