UNIT	COOLING TOWER	
MODEL #	AT 314-3M72	SCALE NTS



DWG. # REV. T4147236-DRA-ST DATE_{12/13/2025} SERIAL #


NOTES:


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE PE DENOTES PLAIN END
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT **DRAWING**

7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]









FACE D

7" [178] 10'-2 1/4' [3105] 11'-10 1/2" [3620] 2" [51] (3) 14" [350] BFW/GVD 18'-5 1/2" [5626] 12'-3 3/4' 8'-3 1/4" [2521] (3) 14" [350] BFW/GVD -(3) 3" [80] MPT 2'-2" [660] 11'-10 1/2" _ [3620] (3) 4" [100] FPT 1'-5 3/8" [441] 17'-8 3/4" [5404] **OVERFLOW** (3) 4" [100] FPT DRAIN 9" [229] 4 1/8" [105] 23'-9" [7239] 13'-11 1/4" 71'-8" [21844] [4248'] **FACE B FACE A**