UNIT **COOLING TOWER** MODEL # SCALE NTS AT 110-2I12


EVAPCO, INC. Evapeo





DWG. # REV. T3282424-DRG-ST DATE 4/23/2024 SERIAL #

## NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT **DRAWING**
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]







DRAWN BY: KDS NO. OF SHIPPING SECTIONS **SHIPPING OPERATING** HEAVIEST SECTION 4200 lbs+ [1910] kg+ 6620 lbs+ [3005] kg+ 11580 lbs+ [5255] kg+ WEIGHT WEIGHT WEIGHT