NIT OOOL N.C. TOWER		8	DWG. #	REV
COOLING TOWER	→ FVΔPCO 1	INC. evapco	ATL4BI48304E5T-DRD-DS	- DATE:
AT 248-4S30-EV SCALE N	rs LVAI CO, I			8/29/2025 '-4"
NOTES 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS CASING SECTION 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAW 5. 3/4" [19mm] DIA. MOUNTING HOLES. REFI RECOMMENDED STEEL SUPPORT DRAW 6. DIMENSIONS LISTED AS FOLLOWS ENGLISH FT-IN [METRIC] [mm] 7. FOR BOTTOM INLET SPECIFICATIONS, SEE DETAIL.	INGS) ER TO /ING 2 5/8" [67]	18'-2 1/2" [5550] (2) ACCESS DOOR FACE B PLAN VIEW DM OF UNIT 5'-11 3/8" [1813] 7'-6"	PACE C [10]	016] 10 1/8" [3000] 14'-3 3/4" [4362] (4) 16" [400] BFW/GVD EQUALIZER FACE D
[14	-2'-1 1/4" [641] -1'-5 3/8" [441] -3 5/8" [92] -1'-11 3/4" [603] -2'-9 3/8" [848]	7'-0" [2134] 6'-0 1/8" [1832] 31'-9 1/2" [9690] 8'-7 1/8" [2619] 10'-2 1/4" [3105] FLUID OUT 1 3/8" [35]		3'-0 3/8" [924]
SHIPPING WEIGHT 138020 lbs+ [62605] kg+	OPERATING WEIGHT 191080 lbs+ [86675] kg+	HEAVIEST SECTION 12320 lbs+ [5590] kg+	NO. OF SHIPPING SECTIONS 14	DRAWN BY: JLG