

This document is the property of Evapco, Inc. It should not be copied or disclosed without prior written authorization.

MODEL #	U-EJETME2-2183H0100F1JA
---------	-------------------------

DWG. # UEJETM2-SE-16,18

DATE	7/29/2025
------	-----------



Technical drawing of the front view of a device. The drawing shows a rectangular frame with two circular fans mounted inside. The dimensions are as follows:

- Total width: $126 \frac{3}{8}$
- Distance from left edge to first fan center: 6
- Distance between fan centers: 42 (indicated by two arrows, each labeled $* 42$)
- Distance from second fan center to right edge: $36 \frac{3}{8}$
- Distance from left edge to first fan center (bottom): 4
- Distance between fan centers (bottom): 42
- Distance from second fan center to right edge (bottom): $38 \frac{5}{8}$

Technical drawing of the front view of a mechanical part. The drawing includes the following dimensions and labels:

- Overall width: $45 \frac{3}{8}$
- Top flange width (excluding side tabs): $* 41 \frac{3}{8}$
- Side tab width (left): $\frac{3}{4}$
- Side tab width (right): $\frac{3}{4}$
- Distance from right side tab to centerline: $4 \frac{7}{8}$
- Distance from centerline to top edge of main body: $** 7 \frac{1}{4}$
- Height of main body: $54 \frac{5}{8}$
- Overall height: $60 \frac{3}{4}$
- Bottom flange width (excluding side tabs): 55
- Side tab width (left): $\frac{1}{4}$
- Side tab width (right): $1 \frac{1}{4}$
- Overall bottom width: $57 \frac{1}{2}$
- Label "AIR FLOW" with an arrow pointing left, indicating the direction of airflow through the central opening.
- Label "PT IN" with an arrow pointing to a small circle on the bottom right, indicating a port inlet.

- 1) * = HANGER HOLE LOCATION.
- 2) RIGHT HAND MODEL SHOWN.
- 3) HANGER HOLES ARE FOR 3/4 INCH THREADED ROD.
- 4) WATER DEFROST ADDS 1 3/4" INCHES TO HEIGHT OF STANDARD UNIT AND CHANGES DRAIN SIZE.
- 5) ALL DIMENSIONS ARE FOR REFERENCE AND SHOULD NOT BE USED FOR PREFABRICATION OF PIPING OR SUPPORTS.
- 6) **= HEIGHT OF SUCTION HEADER AND INSTALLED THERMOWELL FITTING ABOVE CABINET. CUSTOMER IS RESPONSIBLE TO ACCOUNT FOR ADDITIONAL HEIGHT NECESSARY FOR RTD AND ACCESS.

ROOM

1230 lbs+ [560] kg+

1400 lbs+ [640] kg+