UNIT	COOLING TOWER	
MODEL #	AT 110-2I12	SCALE NTS

EVAPCO, INC. Evapeo


DWG. # REV. T3242048-DRF-ST DATE 3/28/2024 SERIAL #

## NOTES:


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT **DRAWING**
- 7. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]




**FACE C** 



**FACE B PLAN VIEW** 





DRAWN BY: KDS NO. OF SHIPPING SECTIONS **SHIPPING** OPERATING HEAVIEST SECTION 6620 lbs+ [3005] kg+ 4200 lbs+ [1910] kg+ 11580 lbs+ [5255] kg+ WEIGHT WEIGHT WEIGHT