UNIT	CONDENSER		EVAPCO, INC.	DWG. #	WZ32M124806-DRB-SRL	REV.	-
MODEL #	ATC-387E	SCALE NTS		SERIAL #		DATE	4/18/2024

NOTES:
1. (M)- FAN MOTOR LOCATION
2. HEAVIEST SECTION IS COIL SECTION
3. MPT DENOTES MALE PIPE THREAD
   FPT DENOTES FEMALE PIPE THREAD
   BFW DENOTES BEVELED FOR WELDING
4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
5. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING
6. DIMENSIONS LISTED AS FOLLOWS:
   ENGLISH FT-IN
   [METRIC] [mm]
7. THE SPRAY PUMP SHOULD BE SIZED FOR 745 GPM [47 L/S] AND AT 4 PSIG [28 kPa] AT THE INLET CONNECTION
8. * - APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF CONNECTING PIPING

Preliminary

FACE C



FACE B

PLAN VIEW

FACE D

FACE A



FACE A



FACE B

SHIPPING WEIGHT	14000 lbs+ [6355] kg+	OPERATING WEIGHT	17230 lbs+ [7820] kg+	HEAVIEST SECTION WEIGHT	10980 lbs+ [4985] kg+	NO. OF SHIPPING SECTIONS	2	DRAWN BY:	AWR